



Product Service

Attestation of Conformity

No. N8A 118771 0004 Rev. 01

Holder of Attestation: **Zhejiang Sunpro Power Technology co., Ltd**

Qinggang Technological Ind.Zone
317606 Yuhuan, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062123505-03

Date, 2023-04-28

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 118771 0004 Rev. 01

Model(s): SPDGxxx-144M10, xxx=520 to 550 in step of 5,
 SPDGxxx-132M10, xxx=480 to 505 in step of 5,
 SPDGxxx-120M10, xxx=435 to 460 in step of 5,
 SPDGxxx-108M10, xxx=390 to 415 in step of 5,
 SPDGxxx-132M12, xxx=635 to 670 in step of 5,
 SPDGxxx-120M12, xxx=580 to 605 in step of 5,
 SPDGxxx-110M12, xxx=530 to 555 in step of 5,
 SPDGxxx-144M, xxx=410 to 460 in step of 5,
 SPDGxxx-120M, xxx=340 to 385 in step of 5,
 SPDGxxx-N144M10, xxx=545 to 580 in step of 5,
 SPDGxxx-N132M10, xxx=510 to 530 in step of 5,
 SPDGxxx-N120M10, xxx=455 to 480 in step of 5,
 SPDGxxx-N108M10, xxx=410 to 430 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, double glass with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class A or Class C according to UL790

Tested according to: EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®